

APPENDIX - VIII

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 2263-63
31/01/23

Date : 31/01/2023

It is certified that an inspection team headed by DR. ARNEST LAL
B.M.O (Name of Officers
with designation) from C.H.C. GAIRATGANJ (Name of
Department/Office) inspected the LITTLE FLOWER HR. SEC
SCHOOL GAIRATGANJ (Name & Address of
the School) on 31.01.2023 and found that the LITTLE FLOWER
HR. SEC. SCHOOL (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of Five years.

Signature with Seal :

Name

Designation


Block Medical Officer
C.H.C. Gairatganj
Distt. Raisen (M.P.)
: Dr. Arnest
: BMO
Gairatganj

To

LITTLE FLOWER HR. SEC. SCHOOL
PUSHPA NAGAR, GAIRATGANJ
RAISEN D.T.

(Name & Address of the Institution)

District Water testing Laboratory, (D.W.T.L.)
Public Health Engineering Department.P.H.E.D.
Near TahseelSagar
Test Report

Issue No 41

D.W.T.L./PHED/SAG /2026-27

Issue Date 29/09/2026

Nature of sample :- Drinking Water Sample / Others	Not sampled by District Water testing Lab		Unique Identification No.	
Sender's name and address: LITTLE FLOWER HR.SEC.SCHOOL GAIRATGANJ	Sender's letter no.	377	Sender's letter Date	28/09/2026
	DWTLRef. No	41/26	DWTL receipt date	28/09/2026
	Date of analysis started	28/09/2026	Date of analysis completed	29/09/2026
	Quantity Of sample	2 LTR		

Sample details

No.	Block	Panchayat	Village	Location
1				DRINKING WATER
2				
3				
4				
5				

RESULTS

No.	Characteristics ,unit and test methods	BIS -10500:2012		Test Results				
		Desirable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4					
1*	Chloride as Cl in mg/l, (IS 3025 Part 32)	250	1000	22				
2*	Total Alkalinity as CaCO ₃ in mg/l, (IS 3025 Part 23)	200	600	32				
3*	Calcium as Ca++,in mg/l, (IS 3025 Part 40)	75	200	25				
4*	Magnesium as Mg++,in mg/l, (IS 3025 Part 46)	30	100	6.9				
5*	Total hardness as CaCO ₃ in mg/l, (IS 3025 Part 21)	200	600	138				
6	pH (pH scale)	6.5 to 8.5	6.5 to 8.5	7.1				
7	Iron as Fe Mg/l	1.0	1.0	0.14				
8	Nitrate as NO ₃ Mg/l	45	45	2.2				
9	Fluoride as F Mg/l	1.0	1.5	0.41				
10	TDS Mg/l	500	2000	60.19				
11	Turbidity NTU	1.0	5.0	0.0				
12	Sulphate as SO ₄ Mg/l	200	400	8.1				
13	Manganese as MnMg/l	0.1	0.3	0.0				
14	Faecal Coliform (TTC) per 100 ml	NIL		-				
15	Total Coliform per 100 ml	NIL for treated water and water in distribution system		NIL				
16	ArsenicBy Kit Mg/l	0.01	0.01	0.0				

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 7 days from the date of issue of report. (For tests from S.No. 1 to 17)
5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
6. The tests marked with an * are accredited by NABL.

Remark:-

Reviewed

for
Authorised Signatory
Asstt. Engineer
P. H. E. Sub Div. 1
Sagar (M. T)